


# Generator Interconnection Request Solar Generating Facility Data

**Generating Facility Name:** \_\_\_\_\_ **Date:** \_\_\_\_\_

**Interconnection Service Capacity (Maximum Net Export Capability at POD):** \_\_\_\_\_ MW

- 1. Simplified One-Line Diagram.** This should be similar to Figure below. If it is different, please mark the difference on the diagram below.



**2. Generator Interconnection Tie Line.**

*Provide either absolute or per unit impedance values.*

- a) Point of Interconnection (utility substation/line name): \_\_\_\_\_
- b) Line voltage: \_\_\_\_\_ kV, line rating at 95°F ambient: \_\_\_\_\_ MVA, line length: \_\_\_\_\_ Miles / Feet
- c)  $R_1 =$  \_\_\_\_\_ ohm or \_\_\_\_\_ pu on 100 MVA and line kV base (positive sequence)
- d)  $X_1 =$  \_\_\_\_\_ ohm or \_\_\_\_\_ pu on 100 MVA and line kV base (positive sequence)
- e)  $B_1 =$  \_\_\_\_\_  $\mu$ F or \_\_\_\_\_ pu on 100 MVA and line kV base (positive sequence)
- f)  $R_0 =$  \_\_\_\_\_ ohm or \_\_\_\_\_ pu on 100 MVA and line kV base (zero sequence)
- g)  $X_0 =$  \_\_\_\_\_ ohm or \_\_\_\_\_ pu on 100 MVA and line kV base (zero sequence)
- h)  $B_0 =$  \_\_\_\_\_  $\mu$ F or \_\_\_\_\_ pu on 100 MVA and line kV base (zero sequence)

**3. Main Transformer.** Number of main transformers: \_\_\_\_\_

*Provide data for either two-winding or three-winding transformer as appropriate.*

**Two-Winding Main Transformer Data (as applicable)**

- a) Rating at 95°F ambient (OA/FA/FA): \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_ MVA
- b) Nominal Voltage for each winding (Low/High): \_\_\_\_\_ / \_\_\_\_\_ kV
- c) Winding Connections (Low/High): Delta or Wye / Delta or Wye
- d) Available tap positions: \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_ kV or \_\_\_\_\_ % \_\_\_\_\_ # of taps.
- e) Positive sequence impedance  $Z_1$ : \_\_\_\_\_ %, \_\_\_\_\_ X/R on self-cooled (OA) MVA rating above.

## Generator Interconnection Request Solar Generating Facility Data

- f) Zero sequence impedance  $Z_0$ : \_\_\_\_\_ %, \_\_\_\_\_ X/R on self-cooled (OA) MVA rating above.
- g) For pad mount transformer, construction: 3 / 4 / 5 -legged

### Three-Winding Main Transformer Data (as applicable)

- h) GSU connection and winding (attach diagram and mark to reference this form).

	H Winding Data	X Winding Data	Y Winding Data
Full load ratings at 95°F ambient (i.e. OA/FA/FA)	_____/_____/_____ MVA	_____/_____/_____ MVA	_____/_____/_____ MVA
Rated winding voltage base	_____ kV Delta or Wye connected	_____ kV Delta or Wye connected	_____ kV Delta or Wye connected
Tap positions available	_____/_____/_____/_____ _____/_____ kV	_____/_____/_____/_____ _____/_____ kV	_____/_____/_____/_____ _____/_____ kV
Present Tap Setting (if applicable)	_____ kV	_____ kV	_____ kV
Neutral solidly grounded? (or) Neutral Grounding Resistor (if applicable)	_____ _____ Ohms	_____ _____ Ohms	_____ _____ Ohms
BIL rating	_____ kV	_____ kV	_____ kV

### Three-Winding Main Transformer Impedance Data (as applicable)

	H-X Winding Data	H-Y Winding Data	X-Y Winding Data
Transformer base for impedances provided	_____ MVA	_____ MVA	_____ MVA
Positive sequence impedance $Z_1$	_____ % _____ X/R	_____ % _____ X/R	_____ % _____ X/R
Zero sequence impedance $Z_0$	_____ % _____ X/R	_____ % _____ X/R	_____ % _____ X/R

### Additional Data for either Two-Winding or Three-Winding Main Transformer

- i) Air core inductance: \_\_\_\_\_ pu (From H winding side on \_\_\_\_\_ MVA Base)
- j) No load test results:
- 1) Rated Voltage of Winding at which current is determined: \_\_\_\_\_ kV
  - 2) Current at 90% / 100% / 110% of rated voltage: \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_ A
  - 3) Losses at 90% / 100% / 110% of rated voltage: \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_ W

## Generator Interconnection Request Solar Generating Facility Data

k) Provide Rapid Voltage Change (RVC) mitigation strategy on main transformer energization (**required** if valid air core inductance and no load test data cannot be provided, or if deficiency is identified):

Main Transformer to be energized from the high side with a switching device that is equipped with pre-insertion resistors.

Other mitigation: \_\_\_\_\_

#### 4. Collector System Equivalent Model.

*Provide either absolute or per unit impedance values.*

a) Collector system voltage = \_\_\_\_\_ kV

b) Collector system equivalent model rating at 95°F ambient = \_\_\_\_\_ MVA

c)  $R_1$  = \_\_\_\_\_ ohm or \_\_\_\_\_ pu on 100 MVA and line kV base (positive sequence)

d)  $X_1$  = \_\_\_\_\_ ohm or \_\_\_\_\_ pu on 100 MVA and line kV base (positive sequence)

e)  $B_1$  = \_\_\_\_\_  $\mu$ F or \_\_\_\_\_ pu on 100 MVA and line kV base (positive sequence)

f)  $R_0$  = \_\_\_\_\_ ohm or \_\_\_\_\_ pu on 100 MVA and line kV base (zero sequence)

g)  $X_0$  = \_\_\_\_\_ ohm or \_\_\_\_\_ pu on 100 MVA and line kV base (zero sequence)

h)  $B_0$  = \_\_\_\_\_  $\mu$ F or \_\_\_\_\_ pu on 100 MVA and line kV base (zero sequence)

#### 5. Inverter Step-Up Transformers. Number of inverter transformers: \_\_\_\_\_

*Provide data for either two-winding or three-winding transformer as appropriate*

##### **Two-Winding Inverter Step-Up Transformer Data (as applicable):**

a) Nameplate Rating (at 95°F ambient): \_\_\_\_\_ MVA

b) Maximum Rating (if applicable): \_\_\_\_\_ MVA

c) Nominal Voltage for each winding (Low/High): \_\_\_\_\_ / \_\_\_\_\_ kV

d) Winding Connections (Low/High): Delta or Wye / Delta or Wye

e) Available taps: \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_ kV **or** \_\_\_\_\_ % \_\_\_\_\_ # of taps.

f) Positive sequence impedance ( $Z_1$ ) \_\_\_\_\_ %, \_\_\_\_\_ X/R on MVA rating above.

g) Zero sequence impedance ( $Z_0$ ) \_\_\_\_\_ %, \_\_\_\_\_ X/R on MVA rating above.

## Generator Interconnection Request Solar Generating Facility Data

### Three-Winding Inverter Step-Up Transformer Data (as applicable)

h) GSU connection and winding (attach diagram and mark to reference this form).

	H Winding Data	X Winding Data	Y Winding Data
Full load ratings at 95°F ambient (i.e. OA/FA/FA)	____/____/____ MVA	____/____/____ MVA	____/____/____ MVA
Rated winding voltage base	____ kV Delta or Wye connected	____ kV Delta or Wye connected	____ kV Delta or Wye connected
Tap positions available	____/____/____/ ____/____ kV	____/____/____/ ____/____ kV	____/____/____/ ____/____ kV
Present Tap Setting (if applicable)	____ kV	____ kV	____ kV
Neutral solidly grounded? (or) Neutral Grounding Resistor (if applicable)	____ ____ Ohms	____ ____ Ohms	____ ____ Ohms
BIL rating	____ kV	____ kV	____ kV

### Three-Winding Inverter Step-Up Transformer Impedance Data (as applicable)

	H-X Winding Data	H-Y Winding Data	X-Y Winding Data
Transformer base for impedances provided	____ MVA	____ MVA	____ MVA
Positive sequence impedance $Z_1$	____ % ____ X/R	____ % ____ X/R	____ % ____ X/R
Zero sequence impedance $Z_0$	____ % ____ X/R	____ % ____ X/R	____ % ____ X/R

### 6. Inverter Data.

- a) Number of Inverters: \_\_\_\_\_
- b) Inverter maximum capability at 95°F/35°C or higher: \_\_\_\_\_ kW/ \_\_\_\_\_ kVA
- c) Describe inverter reactive capability: \_\_\_\_\_
- d) Inverter short circuit ratio limit: \_\_\_\_\_
- e) Inverter Manufacturer and Model #: \_\_\_\_\_
- f) Provide with this form the inverter specification sheet with reactive capability curve.  Attached
- g) Type of photovoltaic system: Fixed or Tracked

## Generator Interconnection Request Solar Generating Facility Data

### 7. Plant Reactive Power Compensation (beyond the inverters built-in reactive capability).

- a) Type of reactive compensation device(s): Fixed or Dynamic
- b) Individual fixed shunt reactive device type: \_\_\_\_\_
  - Number and size of each: \_\_\_\_\_ × \_\_\_\_\_ MVA
- c) Dynamic reactive control device (e.g., SVC, STATCOM): \_\_\_\_\_
- d) Control range at rated MW output: \_\_\_\_\_ Mvar (lead and lag)
- e) Control mode (e.g., voltage, power factor, reactive power): \_\_\_\_\_
- f) Regulation point: \_\_\_\_\_
- g) Describe the overall reactive power control strategy: \_\_\_\_\_

### 8. Dynamic Modeling Data.

- a) Provide with this form 2<sup>nd</sup> generation standard/generic dynamic models for the inverter, and any additional dynamic reactive control devices.     **Standard/Generic Models Attached** 
  - Include plant volt/var control function model and active power/frequency control function model.
  - All the associated files, including source code for user-written models, for dynamic modeling should be in PSS/E version 33, and must be shareable on an interconnection-wide basis to support use in the interconnection-wide cases.
  - Model parameters must be set for the inverter to operate according to PowerSouth's requirements for Inverter-Based Generation, including:
    - (1) Voltage response and ride-thru settings.
    - (2) Frequency response and ride thru settings.
    - (3) Control mode (as determined by PowerSouth)
    - (4) Q-Priority (as determined by PowerSouth)
    - (5) Any plant-level real power limits.
- b) In addition, if the standard model does not accurately represent the equipment's dynamic response, user-written models should be submitted along with the standard model. The user-written models must include the model characteristics, including block diagrams, values and names for all model parameters and a list of all state variables.

**User-Written Models Attached**

## Generator Interconnection Request Solar Generating Facility Data

### 9. Three-Phase Modeling Data.

- a) Provide with this form a three-phase model for the for the inverter, and any additional dynamic reactive control devices.      **Attached**

### 10. Short Circuit Contribution of the Generating Facility at the Point of Interconnection.

- a) Maximum Three Phase Fault Current: \_\_\_\_\_ Amps and Duration: \_\_\_\_\_
- b) Maximum Single Line to Ground Fault\* Current: \_\_\_\_\_ Amps and Duration: \_\_\_\_\_  
\* Single Line to Ground Fault at the Point of Interconnection with ties to utility at the POI open.

### 11. Harmonic Distortion of the plant at Point of Interconnection.

- a) Total Harmonic Current Distortion: \_\_\_\_\_ %
- b) Provide with this data form the individual harmonic currents through 49<sup>th</sup> harmonic, in % of fundamental current rating.      **Attached**